

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7254-1595:110 Page 1 of 1

**CATEGORY:** Heat Detector (Single/Multiple)

**LISTEE:** Invensys Climate Controls Americas, 191 E. North Ave., Carol Stream, IL 60188-2064  
Contact: Tom Barakat (630) 260-7262 FAX (630) 260-7290

**DESIGN:** Model ADH single and multiple station, 120 VAC with battery back up, fixed temperature heat detector. The unit is designed to be used as an added source of information and should be used in conjunction with smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC, 9 VDC battery back up, 135<sup>0</sup>F fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as AC powered with battery back up, single and multiple station fixed temperature heat detector.

**NOTE:** Formerly 7254-1474:104, 7254-1093:119

02-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**